



Warren Electric
Cooperative, Inc

RIGHT-OF-WAY CLEARING SPECIFICATIONS

All work shall be done using current arboricultural practices

Single Phase line sections (<14400 volts) require a thirty (30) foot width (15' each side of pole)

Three-Phase line sections (< 34500 volts) require a forty (40) foot width (20' each side of pole)

IF VIEWING FROM WEBSITE, CLICK ON "DRAWING" TO VIEW THIS PORTION

Refer to the back of this sheet for complete detailed specifications and a list of area tree service providers*.



RIGHT-OF-WAY CLEARING SPECIFICATIONS

All work shall be done using current arboricultural practices

Before Construction:

The right-of-way shall be prepared such that the right-of-way is cleared "ground to sky" to the width specified.

- Trees fronting each side of the right-of-way shall be trimmed symmetrically or removed.
- Dead trees beyond the right-of-way that may strike the line when falling shall be removed.
- Live trees beyond the right-of-way that are leaning and may strike the line when falling shall be adequately topped or removed.
- Underbrush shall be removed.
- Stumps, shoots, and stems shall be cut such that no more than one (1) inch extends above ground level.
- Miscellaneous debris and obstacles shall be removed

Right-of-way work shall meet WEC specifications and inspection prior to any construction activities being scheduled. Additional charges will apply for subsequent re-inspection visits prior to construction.

After Construction:

Right-of-way shall be periodically maintained by WEC on a six (6) year cycle or as needed.

This involves chemical treatment as well as removing new trees and underbrush to the width specified.

Right-of-way must remain open and orderly for WEC construction and maintenance activities to the line.

Field personnel patrolling or working on lines do not need additional hazards in the dark or under the snow.

The following are examples of items not allowed in the corridor. Line relocation charges will apply unless corrective action is taken by the member.

- Houses, garages, sheds
- Well heads (water, gas, oil, etc)
- Propane tanks
- Septic systems
- Obstacles (wood piles, clothes lines, abandoned vehicles)

Member attachments to poles (lights, satellites, signs, etc) are strictly prohibited.

AREA TREE SERVICE PROVIDERS*

A Top Notch Tree & Stump Service	800-322-5303
Allegheny Tree Experts	814-563-7175
Burke Tree Service	814-726-1419
Hazlett Tree Service	814-967-4321
Shippee Services	814-563-7479
Tremblay Tree Service	814-489-3792

*WEC provides this list only as a convenience to the members and does not endorse, recommend, guarantee, or otherwise warranty work performed